

ADDENDA TO BID DOCUMENT

SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF AIR-CONDITIONING
AND EXHAUST SYSTEM AT MULTIPURPOSE HALL, KHS AGRA

ADDENDA NO-I

May, 2016



EdCIL (India) Limited

[A Government of India Enterprise]
Under Ministry of Human Resource Development
Plot 18 A, Sector 16 A, NOIDA - 201 301
Uttar Pradesh, INDIA
Tel: 91-120-2512001 to 2512006 (EPABX)
Tel: 91-120-4310840 (Direct)
Fax: 91-120-2515372, 2515485

S.No	Para / Clause No.	Page No.	Items	TO be Read as
1.	Schedule of Quantities	2	Sr. No. 1	a) Supply, installation, testing and commissioning of Packaged type air Cooled Air-conditioning Units (With Green Refrigerant-R-410) consisting of outdoor Condensing Unit and Indoor Evaporative Unit with control panel of the unit and all internal electrical power and control wiring accessories and ancillary items like thermostats/MS frames etc of below specified cooling capacity, Complete in all respect as per drawings & specifications including all civil minor work.
2.	Specifications	Section 4 Page 10	Clause 5	Insulation of drain piping shall be carried out using 9mm thick insulation tube of closed cell nitrile rubber having a K value of 0.034 W/(M.K) at mean temperature of 10 degree centigrade and a density of not less than 80 Kg/m3.
		Section 4 Page 11	Clause 6	Suction line of the refrigerant shall be insulated with 19 mm insulation as specified.
		Section 9 Page 24	Sr. No. 2	Makes of Centrifugal fans – Krugar/Nicotra/Comefrei
		Section 9 Page 24	-	Makes of GI Pipes shall be Tata / Jindal .
3.	Technical Bid, Conditiios of Contract	1, 3 (Technical Bid) 1, (Conditions of Contract)	As Applicable	Period of completion shall be read as 03 Months .